



Missouri Department Of Natural Resources
Public Drinking Water Program
P.O. Box 176
Jefferson City, MO 65102 (573)751-5331



Public Water System Radionuclide Results

PWS Name : BOONE CO PWS# 9 PWS ID : MO3024058
Mail to : ROGER BALLEW County : BOONE
391 N RANGELINE RD
COLUMBIA, MO 65201-0000
Please notify us of any name and address changes

Lab Sample ID : 0522
Date Collected : 01/24/2005
Time Collected : 08:35:00
Sample Type : Routine
Location : EP HARG -2001 OLIVET
Source : GW
Collector : TIM DARLING
Collection Technique : Grab
Laboratory : ST LOUIS COUNTY DEPT OF HEALTH

Contaminant	Result	Analysis Date	EPA Method Code
GROSS ALPHA PARTICLE ACTIVITY, TOTAL	25.3 PCI/L	03/14/2005	900
Additional testing is required because the analysis result exceeds the screening limit. You will receive a follow-up sample kit.			
RADIUM-226	9.2 PCI/L	03/14/2005	903.1
Additional testing is required because the analysis result exceeds the screening limit. You will receive a follow-up sample kit.			
RADIUM-228	< 1 PCI/L	03/14/2005	904.4

A result of < (less than) a specified quantity means the concentration was either zero or less than the analytical detection level.

Monday, July 11, 2005