



Missouri Department Of Natural Resources
Public Drinking Water Program
P.O. Box 176

Jefferson City, MO 65102 (573)751-5331



Public Water System Radionuclide Results

PWS Name : BOONE CO PWSD #9
Mail to : ROGER BALLEW
391 N RANGELINE RD
COLUMBIA, MO 65201-0000

PWS ID : MO3024058

County : BOONE

Please notify us of any
name and address changes

Lab Sample ID : 04358
Date Collected 08/11/2004
Time Collected : 13:30:00
Sample Type Special
Location : EP HARG WELL
Source : GW
Collector : RICHARD HARRIS
Collection Technique : Grab
Laboratory : ST LOUIS COUNTY DEPT OF HEALTH

Contaminant	Result	Analysis Date	EPA Method Code
GROSS ALPHA PARTICLE ACTIVITY, TOTAL	19 PCI/L	09/03/2004	900
RADIUM-226	8.4 PCI/L	09/03/2004	903.1
RADIUM-228	1.2 PCI/L	09/03/2004	904.4

A result of < (less than) a specified quantity means the concentration was either zero or less than the analytical detection level.

Wednesday, October 20, 2004